

BOARD OF COUNTY COMMISSIONERS
SARPY COUNTY, NEBRASKA

RESOLUTION ACCEPTING AMERICANS WITH DISABILITIES ACT ("ADA")
TITLE II AND TITLE III SELF EVALUATION AND TRANSITION PLAN

WHEREAS, pursuant to Neb. Rev. Stat. § 23-104(6), the County has the power to do all acts in relation to the concerns of the county necessary to the exercise of its corporate powers;

WHEREAS, pursuant to Neb. Rev. Stat. § 23-103, the powers of the County as a body are exercised by the County Board;

WHEREAS, to determine compliance with Title II and Title III of the ADA (42 U.S.C.A. §§ 12132 and 12182 *et seq.*), the County completed a self-evaluation and based upon the results of that self-evaluation ("Self-Evaluation"), developed a transition plan ("Transition Plan") for full compliance under the ADA;

WHEREAS, the County provided the public with an opportunity to comment on the Self-Evaluation and Transition Plan during an open comment period from September 30, 2014 through October 15, 2014;

WHEREAS, the Self-Evaluation and Transition Plan were presented at a public hearing before the County Board on September 30, 2014 and October 21, 2014;

WHEREAS, the Self-Evaluation and Transition Plan are available for public viewing at the Sarpy County Human Resources Department and www.sarpy.com; and


WHEREAS, the County desires to accept the Self-Evaluation and Transition Plan.

NOW, THEREFORE, BE IT RESOLVED by the Sarpy County Board of Commissioners that this Board hereby accepts the Self-Evaluation and Transition Plan.

The above Resolution was approved by a vote of the Sarpy County Board of Commissioners at a public meeting duly held in accordance with applicable law on the 21st day of October, 2014.


 Sarpy County Board Chairman

Attest
 SEAL


 County Clerk

Sarpy County Board of Commissioners

1210 GOLDEN GATE DRIVE
PAPILLION, NE 68046-2895
593-4155

www.sarpy.com

ADMINISTRATOR Mark Wayne

DEPUTY ADMINISTRATOR Scott Bovick

FISCAL ADMIN./PURCHASING AGT. Brian Hanson



COMMISSIONERS

Don Kelly District 1
Jim Thompson District 2
Tom Richards District 3
Brenda Carlisle District 4
Jim Warren District 5

MEMO

October 21, 2014

TO: Sarpy County Board of Commissioners

FROM: Scott Bovick, Deputy County Administrator

RE: Public Hearing and Resolution adopting Americans with Disabilities Act (ADA) Self-Evaluation and Transition Plans

On September 30, 2014 the County Board heard a presentation from staff and held a public hearing on the County's ADA Self-Evaluation and Transition Plan. After the hearing, a link to the documents was placed on the front page of the County's website and a comment period was open from October 1 through October 15, providing the public an opportunity to view the documents and provide input. The Self-Evaluation and Transition Plan are now ready for final adoption by the County Board following a second public hearing.

As you are aware, the purpose of the Self-Evaluation is to identify public facilities and infrastructure that are not compliant with ADA regulations. Then the Transition Plan lays out the County's plan to address those areas to achieve compliance. The Transition Plan includes estimated costs and proposed timelines for completing improvements and will be factored into the budget process in upcoming fiscal years. In some instances where the county occupies leased space, the needed improvements may be the responsibility of the landlord. Staff will ensure those improvements are made in accordance with the Transition Plan.

We want to again thank Facilities Management and Public Works staff for all their work in conducting the Self-Evaluation inspections and preparing the Transition Plan.

Please feel free to contact me if you have any questions. Thank you.


Scott Bovick, Deputy County Administrator

Cc: Deb Houghtaling, Pat Dowse, Bonnie Moore, Karen Buche, Ross Richards, Michael Kosa, Denny Wilson

Americans with Disabilities (ADA)

Self-Evaluation & Transition Plan

Public Hearing & Resolution
October 21, 2014



ADA Self-Evaluation:

- Inventory (and details) of facilities where structural modifications are needed to make facilities accessible to persons with disabilities
- Foundation for Transition Plan
- Maintain in file/available for public inspection for 3 yrs from date of completion

ADA Transition Plan:

- Set forth steps necessary to complete modifications identified through self-evaluation (those areas not covered in a previously developed plan)
- Provide a schedule for completing modification



Americans with Disabilities Act
Accessibility Survey
Self-Evaluation and Transition Plan

Sarpy County Sheriff's Office
8835 Platteview Road
Papillion, Nebraska 68046




Prepared by
Sarpy County Facilities Management
1210 Golden Gate Dr
Papillion, Nebraska 68046
Ph: 402-588-2382
Fax: 402-593-5793



Facility Name: Sarpy County Sheriff's Office Priority 1 - Approach and Entrance

**1.10 Are accessible spaces identified with a sign that includes the International Symbol of Accessibility?
Is the bottom of the sign at least 60 inches above the ground?**

| | |
|--------------------------------|---|
| Code | 502.6 Identification |
| Code Description | Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation "van accessible." Signs shall be 60 inches minimum above the finish floor or ground surface measured to the bottom of the sign. |
| Finding | Accessible spaces are identified with a sign that includes the International Symbol of Accessibility. The bottom of the signs are 60" above the ground. |
| Compliant? | YES |
| Recommended Repair (if needed) | N/A |





Typical Signage

Facility Name: Sarpy County Sheriff's Office Priority 2 - Access to Goods and Services

Sales & Service Counters - banks, stores, dry cleaners, auto repair shops, fitness clubs, etc.

2.76 Is there a portion of at least one of each type of counter that is:
 No higher than 36 inches above the floor?
 At least 36 inches long?

| | |
|--------------------------------|--|
| Code | 904.4.1 Parallel Approach |
| Code Description | A portion of the counter surface that is 36 inches long minimum and 36 inches high maximum above the finish floor shall be provided. A clear floor or ground space complying with 305 shall be positioned for a parallel approach adjacent to the 36 inch minimum length of counter. |
| Finding | There is a portion of at least one of each type of counter that is no higher than 36" above the floor and at least 36" long. |
| Compliant? | YES |
| Recommended Repair (if needed) | N/A |





Accessible Portion of Counter


Facility Name: Sarpy County Sheriff's Office Priority 3 - Toilet Rooms

Lavatories

Note: 2010 Standards refer to sinks in toilet rooms as lavatories.

3.21 Does at least one lavatory have a clear floor space for a forward approach at least 30 inches wide and 48 inches long?

| | |
|--------------------------------|---|
| Code | 506.2 Clear Floor Space, 305.3 Side |
| Code Description | 506.2 - A clear floor space complying with 305, positioned for a forward approach, and knee and toe clearance complying with 306 shall be provided. 305.3 - The clear floor or ground space shall be 30 inches minimum by 48 inches minimum. |
| Finding | All toilet rooms have at least one lavatory that has a clear floor space for a forward approach that is at least 30" wide and 48" long. |
| Compliant? | YES |
| Recommended Repair (if needed) | N/A |







Admin Lavatory

Facility Name - Sarpy County Sheriff's Office Transition Plan

Sheriff's Office Transition Plan

| Priority # | Deficiencies Description | Proposed Corrective Action | Projected Cost | Anticipated Completion Date | Actual Cost |
|--------------|---|---|-------------------|---|---------------|
| 1.46 | All entrance doors take longer than 5 seconds to close. | Adjust closers. | \$100.00 | 2014-09 | |
| 1.49 | Edges of mats are not securely attached. | Securely attach mat edges. | \$200.00 | 2014-09 | |
| 2.21 | There are no "van accessible" signs at van accessible spaces. | Add "van accessible" signs. | \$500.00 | 2014-09 | |
| 2.23 | The level landing at the top of the ramp is not long enough. | Alter ramp. | \$0.00 | Unachievable due to excessive scope complication. | |
| 2.45 | Public and assembly doors require too much force to open. | Adjust closers. | \$100.00 | 2017-07 | |
| 2.46 | Doors close too quickly. | Adjust closers. | \$100.00 | 2017-07 | |
| 2.67 | Work surfaces don't extend far enough under the surface. | Provide accessible accommodation. | \$2,600.00 | 2017-07 | |
| 2.70 | Bench is too shallow and does not have back support. | Replace or alter bench. | \$600.00 | 2017-07 | |
| 2.81 | Operable parts of the sink are too high. | Lower sink. | \$2,000.00 | 2017-07 | |
| 2.92 | Operable parts are too high; cannot be operated without tight grasping. | Replace lower dispenser. | \$100.00 | 2017-08 | |
| 3.5 | Clear floor space centered on tactile characters is too shallow. | Reposition signs. | \$100.00 | 2019-11 | |
| 3.21 | Doors require more than 5 pounds force to open. | Adjust closers. | \$100.00 | 2019-11 | |
| 3.22 | Restroom doors take longer than 5 seconds to close. | Adjust closers. | \$100.00 | 2019-11 | |
| 3.19 | Distance between two doors is too short. | Remove inner door or change door swing. | \$1,000.00 | 2019-11 | |
| 3.32 | Not enough upper clearance. | Relocate upper protruding objects. | \$300.00 | 2019-11 | |
| 3.38 | Toilet paper dispensers are located too far forward. | Relocate dispensers. | \$200.00 | 2019-11 | |
| 3.43 | Doors are not self-closing. | Add closers. | \$300.00 | 2019-11 | |
| 4.9 | Bottom leading edge of fountain is too high. | Lower fountain. | \$250.00 | 2020-02 | |
| TOTAL | | | \$7,750.00 | | \$0.00 |





Pedestrian Facilities in the Public Right-Of-Way

Produced by Sarpy County Public Works Department

Executive Summary

One of the components of the Self-Evaluation and Transition Plan is an analysis of pedestrian facilities within County-maintained public rights-of-way. The purpose of this plan is to analyze existing pedestrian facilities, determine and prioritize deficiencies, and develop a strategy to correct deficiencies in a timely manner and within budget constraints. This will ensure that Sarpy County continues to be in compliance with federal and local ADA requirements.

Sarpy County Public Works staff completed an inventory of existing pedestrian facilities to determine where deficiencies exist. Using the information collected in the field investigation, subsequent analysis, and current knowledge about properties adjacent to County rights-of-way, Sarpy County Public Works has prioritized as "Deficient" curb ramp locations to establish the order of curb ramp repairs.

Curb Ramp Prioritization Table

| Project Type | Number of Deficient Ramp Locations | Rough Cost Estimate | Target Completion Date |
|-------------------|------------------------------------|---------------------|--------------------------|
| Priority 1 (High) | 132 | \$180,000 | December 31, 2016 |
| Priority 2 | 142 | \$315,000 | December 31, 2018 |
| Priority 3 (Low) | 55 | \$230,000 | December 31, 2020 |
| Total | 329 | \$725,000 | December 31, 2020 |





66th Street and Ashwood Avenue



NW Corner



NE Corner



SW Corner




SE Corner

Curb Ramp Inspection Form
Sarpy County, Nebraska



Project Name: _____
 N/S Street: 14th St
 E/W Street: Ashwood Ave Photo # 1
 Performed By: _____ Inspection Date: 10/15/14
 Intersection Corner (circle one): NW SE SW
 Number of Ramps on Corner: 1 N/A
 Detectable Warning Strips on Ramps: NO SCORED
 Number of Pedestrian Push Buttons: 1 N/A
 48" landing area in a walk in front of ramps? YES NO
 Is either curb ramp at a low point (ponding)? YES NO

| Description | | Description | |
|-----------------|----------------------------------|-----------------|---|
| A1: <u>1.4%</u> | A2: <u>1.6%</u> Landing Slope | F1: <u>47"</u> | F2: <u>47"</u> Landing Length |
| B1: <u>3.1%</u> | B2: <u>2.5%</u> Ramp Slope | G1: <u>1.4"</u> | G2: <u>1.7"</u> Landing Width |
| C1: <u>3.0%</u> | C2: <u>1.0%</u> Curb Slope | H1: <u>1.0"</u> | H2: <u>1.0"</u> Wdg to crosswalk stripe |
| D1: <u>7.5%</u> | D2: <u>1.7%</u> Left Wing Slope | I1: <u>2.0"</u> | I2: <u>2.0"</u> Distance Between Ramps |
| E1: <u>5.2%</u> | E2: <u>1.5%</u> Right Wing Slope | J1: <u>1.0"</u> | J2: <u>1.0"</u> Distance Landing to Push Button |



Revised 10/2014

Public Hearing held September 30, 2014

Open Public Comment Period held October 1 through
October 15, 2014

Public Hearing October 21, 2014

Resolution to adopt Self-Evaluation and Transition Plan
October 21, 2014

Documents will remain available On-Line or hard copy at
Human Resources

